

APPENDIX XIII

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. Aem / 2023-24 / 950

Dated 22/3/2024

It is certified that an inspection team headed by Kuldeep Singh Inspector (RE)

(Name of Officers with designation) from Public Health Engineering Department

(Name of department / office) inspected the Pathways World School


Matunda Road, Nagar Parishad, Bundi

(Name & Address of the school) on 18/3/24 (date of inspection) and found that the Pathways World School, Matunda Road Bundi (Name of

school) has safe drinking water facilities for the students and members of staff of the institution and in maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt

The above is valid for a period of 1 year

Signature with seal


सहायक अभियन्ता
जन स्वास्थ्य विभाग
नगर उपखण्ड, बूंदी

Name

Shubham Shrivastava

Designation

Assistant Engineer

Name & Address of the office / Department Public

Health Engineering Department
Bundi

To

Pathways World School

Matunda, Nagar Parishad, Bundi

(Name & Address of the Institution)

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department, Regional Laboratory, Kota
Test Report (Chemical Examination of Water)

No. Lab. Tech. (Chem)/2023-24/ 2187
To.

Date:- 22/3/24

Pathway World School
Bundi Matunda Road, Nagar Parishad Bundi


District- Bundi

Sample Not Collected by Lab

Reference No./ Date- N.M / 18.03.2024
Date of Receipt- 18.03.2024

Sample taken by- Sh. Sumeet

Source	Permissible Value as per IS : 10500/2012		R.O.
Location			At School Campus
Village/Town/City			Bundi
Date of Collection			18.03.2024
Date of Examination			20.03.2024
Sample No	Desirable Limit	Permissible limit in absence of alternate Source	PC-185
Note: All results except pH are in mg/L			
pH	6.5 to 8.5	No relaxation	6.57
Turbidity (NTU)	1	5	0.12
Colour	5	15	-
Odour	Agreeable	Agreeable	-
Total Alkalinity (as CaCO ₃)	200	600	8
Total Hardness (as CaCO ₃)	300	600	8
Chloride as (Cl ⁻)	250	1000	10
Nitrate as (NO ₃ ⁻)	45	45	0.040
Fluoride as (F ⁻)	1.0	1.5	0.0370
Total Dissolved Solids	500	2000	33


Senior Chemist
PHED Reg. Laboratory Kota

No. Lab. Tech. (Chem)/2023-24/

Date:-

Copy To :

1- Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

o/c

Senior Chemist
PHED Reg. Laboratory Kota